

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Honeywell GmbH		
Product name	CentraLine EAGLE		
Product model number	CLEA2014B22, CLEA2014B02, CLEA2026B21, CLEA2026B01, CLEA2000B21, CLEA2000B01, CLEA2000B31, CLEA2014B32, CLEA2026B31		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.12
Firmware revision	12-00-04		

Data Link Layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 38400, 57600, 76800, 115200	
	<input type="checkbox"/>	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Network options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input type="checkbox"/> Router, medium: BACnet/IP	
Character sets	<input checked="" type="checkbox"/> UTF-8	<input checked="" type="checkbox"/> ANSI X3.4
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input checked="" type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of: v.1.1 21.08.2012
<input type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of:
<input type="checkbox"/> AMEV profile	As of:


3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS dated 07.02.2014 number VG 2013_7800
<input checked="" type="checkbox"/> AMEV recommendation BACnet v.1.1 As of: 21.08.2012 (see www.amev-online.de)

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30103 (see http://www.bacnetinternational.net/btl)

Stuttgart, 25.04.2017



Dr.-Ing. Bernhard Hall
Vermögen und Bau Baden-Württemberg
Rotebühlplatz 30
70195 Stuttgart
Telefon +49 711 6673-3433
Email Bernhard.Hall@vbv.bwl.de

.....
(AMEV chairman BACnet)



WSP Cert
Dr.-Ing. Harald Bitter &
Dr.-Ing. Frank Bitter PartG.
Kapuzinerweg 7
D-70374 Stuttgart
Telefon +49 711 953922-0
Telefax +49 711 953922-66

.....
(BACnet certification body)